

e-Room® Controller 3E/5S Modbus

EN

Fan-Coil controller for DIN rail with Modbus communication
Ref: RN.573501-000

e-Room® Controller 3I/5O Modbus is a fan-coil controller with remote communication, to install in DIN rail cabinets, used for climate and lighting control, managing both systems depending on the occupation state of a room or zone.

The device is specially designed to provide the maximum comfort as possible and an optimal energy saving level of the installation, adjusting the climate control to achieve the value desired by the user.

The device is including different selectable configurations depending on the installation arrangements, and provides a communication bus and output power to supply a user interface based on a visualization display to manage the climate control. A de-facto standard Modbus communication bus is included on the device to manage remotely the device from the BMS of the building.

Instruction sheet



Main features

- Fan-coil controller designed for 2 and 4 pipes installations.
- Up to nine possible configurations for similar installation arrangements.
- Three self-configurable inputs: Keypad contact/Motion sensor, Window contact, Water temperature (Changeover)/Door contact/External temperature sensor.
- Three relays outputs for fan-coil speeds.
- Two relay outputs for valves (2/4 pipes) + room/courtesy lighting.
- Modbus RTU communication protocol with RS-485 interface for remote BMS management.
- Communication bus with RS-485 interface for display
- Mains power supply.
- Eco mode on unoccupied zone (Off / ECO set-point).
- Configurable real setpoint and user setpoint for heat and cool
- Automatic switch-on for extreme temperatures (over temp. or frost risk).
- Fan-coil type configuration: 3 speed / 1 speed.
- Fan coil speed configurable as blocked on zero demand.
- Heat/Cool setpoint in ECO mode.
- Configurable heat/cool dead band.
- Time to change into stand-by mode when room changes into unoccupied state.

Device configuration for different types of installation

Terminales de las entradas (GRIS)					
Tipo de instalación	Número de tubos	IN1 (2 - 3)	IN2 (4 - 5)	IN3 (6 - 7)	
Opción 1	2	Tarjetero	Ventana	Pulsador iluminación	
Opción 2	2	Tarjetero	Ventana	Tº Agua	
Opción 3	4	Tarjetero	Ventana	Tº Agua	
Opción 4	2	Tarjetero	Ventana	Tº Ext	
Opción 5	4	Tarjetero	Ventana	Tº Ext	
Opción 6	2	Sensor movimiento	Ventana	Contacto Puerta	
Opción 7	4	Sensor movimiento	Ventana	Contacto Puerta	
Opción 8	2	Sensor movimiento	Ventana	Tº Agua	
Opción 9	4	Sensor movimiento	Ventana	Tº Agua	

Terminales de las salidas (ROJO)						
Tipo de instalación	Tipo instalación	10 - 11	10 - 12	10 - 13	OUT1 (14 - 15)	OUT2 (16 - 17)
Opción 1	2	Velocidad I	Velocidad II	Velocidad III	Iluminación	EV FRIO/CALOR
Opción 2	2	Velocidad I	Velocidad II	Velocidad III	Iluminación	EV FRIO/CALOR
Opción 3	4	Velocidad I	Velocidad II	Velocidad III	EV CALOR	EV FRIO
Opción 4	2	Velocidad I	Velocidad II	Velocidad III	Iluminación	EV FRIO/CALOR
Opción 5	4	Velocidad I	Velocidad II	Velocidad III	EV CALOR	EV FRIO
Opción 6	2	Velocidad I	Velocidad II	Velocidad III	Iluminación	EV FRIO/CALOR
Opción 7	4	Velocidad I	Velocidad II	Velocidad III	EV CALOR	EV FRIO
Opción 8	2	Velocidad I	Velocidad II	Velocidad III	Iluminación	EV FRIO/CALOR
Opción 9	4	Velocidad I	Velocidad II	Velocidad III	EV CALOR	EV FRIO

Product installation

The product is designed for DIN rail installation. It should not be installed on shelves, above or near heat or wet sources, or exposed to direct sunlight.

Important:

- For a correct operating of the system it is necessary to install the device separating the very low voltage wires (inputs) of the mains wires (device supply and outputs) in the cabinet.
- Use shielded wire for the communication bus of the BMS system and the inputs of the device.
- Use the correct wires as specified in the installation drawing of the device.

Caution:


- Prior to installing or removing the device, ensure that there is no mains voltage present in the wiring to be connected or near the unit.
- Do not cut or roll up the wires to be connected to the device.
- Do not work on the wiring with wet hands.

- Do not open or drill through the device.
- Keep the device and the supply wires away from moisture and dust.
- Use a damp cloth to clean the device.

Installation steps:

1. Disconnect the supply voltage of the cabinet.
2. Open the cabinet and install the device in the DIN rail placing the black clip at the bottom. Pull down the clip and press the device to insert it into the rail. Release the clip and check the device is correctly fitted.
3. Verify that all the wires are installed following the constructive mounting diagram provided.
4. Check all the wires meet all the specifications and connect them into the female terminals following the installation diagram. Connect the terminals into the device.
5. Connect the power supply and verify the correct operating of the device.
6. Close the cabinet.

Wiring diagram



Herein is defined a functional diagram. It shall be the responsibility of installer to protect properly the installation in accordance with applicable regulations of each country.

Technical features

Supply power

Operating voltage 95-250Vca, 50/60Hz
Maximum rated current 12 mA

Output power supply

Output voltage 12Vcc, ±5%
Maximum rated output current 100 mA

Communications

Interface RS-485
Terminals A-, B+, GND
Protocol Modbus RTU
Transmission speed configurable 1200...115200 Baud
Modbus configuration 8E1, 8O1, 8N1, 8N2

Room bus communication

Interface RS-485
Terminals A-, B+

Digital inputs (IN1, IN2, IN3)

Open circuit voltage 12 Vdc ±5%
Short-circuit current 8,0 mA
Input impedance switched on <75 Ω
Input impedance switched off >355 Ω

Analog inputs (IN3)

Type Resistive
Features NTC interchangeable, 1%
10 KΩ a 25°C (77°F)

Measuring range +5°C a +45°C (+41°F a +113°F)
Resolution 0,5°C

Digital outputs (Fan-Coil, OUT1, OUT2)

Contact type Potential free contact
Normally open
Maximum operating voltage 250 Vac
Maximum current 5 A, resistive load
3 A, inductive load

Ordering numbers

e-Room Controller 3E/5S Modbus RN.573501-000

e-Display, Visualization display with built-in temperature sensor for e-Room Controller RD.970000-000
Plastic frame for e-Display, BTicino white LNA4804BI
Plastic frame for e-Display, BTicino matt aluminum LNA4804TE

e-Sensor Noiseless white frame, Motion sensor flush wall mounting with transistor output, 12-24Vca/Vcc DP.801110-000
e-Sensor Noiseless aluminum frame, Motion sensor flush wall mounting with transistor output, 12-24Vca/Vcc DP.801110-001
e-Detector Noiseless, Motion sensor with transistor output for ceiling mounting, 12-24Vca/Vcc DP.801110-010

Window contact

Plastic window contact, flush mounting. REED type, 125Vac/0,5A, normally closed, diameter 15mm CVP-NC

Related documentation

Configuration manual DMCEN	Operating modes DMFEN
User manual DMUEN	Installation drawings DEC
Detailed instruction sheet INSSEN	

The package of this product is considered as industrial packaging; intended for professional use only.

The manufacturer is not responsible of the incorrect installation or use of the products. Specifications are subject to change without notice

